



**CENTRAL JERSEY COLLEGE PREP
CHARTER SCHOOL**

**LEAD IN DRINKING WATER
ADDITIONAL SAMPLING REPORT**

PERFORMED FOR:

**CENTRAL JERSEY COLLEGE PREP CHARTER SCHOOL
101 METTLERS RD
SOMERSET, NJ 08873**

PERFORMED BY:

**WESTCHESTER ENVIRONMENTAL LLC
1248 WRIGHTS LANE
WEST CHESTER, PA 19380**

MAY 2025



May 6, 2025

Mr. David Master
Central Jersey College Prep Charter School
101 Mettlers Rd
Somerset, NJ 08873

Re: LEAD IN DRINKING WATER ADDITIONAL SAMPLING REPORT

Dear Mr. Master:

Please find enclosed the report for the Lead in Drinking Water Additional Sampling conducted for the Central Jersey College Prep Charter School.

The first draw samples analyzed did not exceed the action limit of 15.5 ug/L. Hence, the corresponding flush samples were not analyzed.

If you have any questions, please contact me at 610-431-7545 or email me at cpiccininni@westchesterenvironmental.com or info@westchesterenvironmental.com.

Sincerely,

Westchester Environmental, LLC

A handwritten signature in black ink, appearing to read 'Christopher Piccininni', is written over a light blue horizontal line.

Christopher Piccininni
Environmental Specialist

TABLE OF CONTENTS

CENTRAL JERSEY COLLEGE PREP CHARTER SCHOOL

1.0	EXECUTIVE SUMMARY	2
2.0	INTRODUCTION	3
3.0	SAMPLING AND ANALYSES	4
4.0	SAMPLE RESULTS	5
5.0	DISCUSSION & RECOMMENDATIONS.....	6
6.0	DISCLAIMER	7



1.0 EXECUTIVE SUMMARY

Westchester Environmental, LLC (WCE) was contracted by Mr. David Master of Central Jersey College Prep Charter School to conduct additional lead in water testing for the school district for the 2024-2025 school year. This sampling event was focused on collecting the remaining outlets found throughout the building.

The additional water sampling was performed on April 12, 2025 by Christopher Piccininni of Westchester Environmental, LLC.

The objective of the sampling was to determine the lead in water levels associated with the school. During this visit, first draw and flush water samples were collected at Central Jersey College Prep Charter School located at 101 Mettlers Road, Somerset, NJ 08873.

None of the first draw samples collected exceeded the lead action level of 15.5 microgram/liter (ug/L) or 15.5 parts per billion (ppb), based on the analysis of lead content using U.S. Environmental Protection Agency (EPA) Method 200.8 for lead in drinking water. Hence, the corresponding flush samples were not analyzed.

Immediate / Short Term Action Required:

No immediate action required

-END OF SECTION-

2.0 INTRODUCTION

The objective of the sampling was to determine the lead in water levels from drinking water outlets located within the Central Jersey College Prep Charter School. During this visit, first draw and flush drinking water samples were collected, following a period of no water use within the building for at least eight hours.

The purpose was to sample and analyze drinking water for lead content. Lead in school drinking water continues to be a serious concern, with children in many schools potentially drinking water with dangerous levels of lead. Even when water entering a facility meets all federal and state public health standards for lead concentrations, older plumbing materials found in schools can contribute to elevated lead levels in the drinking water.

The New Jersey Department of Environmental Protection's (NJDEP) action level for lead in drinking water is set at 15. However, for the purposes of compliance, any concentration greater than 15 µg/L (as defined as greater than or equal to 15.5 µg/L) is considered to exceed the lead action level. If sampling exceeds the level, then the action will need to be taken.

The Environmental Protection Agency (EPA) itself states that 15 ug/L is not a health-based standard, but rather based on what is feasible for water systems to achieve. According to the EPA, given present technology and resources, this level is the lowest level to which water systems can reasonably be required to control this contaminant should it be present in drinking water.

On October 8, 2024, the EPA announced the finalization of key improvements to the Lead and Copper Rule (LCR), which introduces new regulations that will reshape how public water suppliers manage lead service lines. These changes are critical to protecting public health and will become effective in late 2027, three years after their publication.

One of the most significant changes is the reduction of the lead action level to 10 ug/L. Water systems that exceed this threshold must take immediate corrective actions, including notifying the public, implementing corrosion control treatments, and expediting lead service line replacement.

-END OF SECTION-

3.0 SAMPLING AND ANALYSES

During this sampling event, seventeen first draw samples, seventeen flushes and one field blank were collected.

All the collected samples were labeled with a unique identification number and transported to Suburban Laboratory for analysis of lead in drinking water using EPA Method 200.8. Suburban Testing Labs located at 1037F MacArthur Rd, Reading, PA 19605, is a NJ certified Lead in Drinking Water testing facility.

The following guidance documents were followed for sampling:

1. New Jersey Department of Education N.J.A.C. 6A:26
2. The USEPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water as well as the Safe Drinking Water Act of 1974".

-END OF SECTION-

4.0 SAMPLE RESULTS

The table below shows the first draw concentrations of lead (microgram per liter) at sampled locations. The NJDEP establishes 15.5 ug/L as the lead action limit. No first draw sample exceeded the action limit of 15.5 micrograms per liter (ug/L).

Central Jersey College Prep Charter School

Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
1 CJCP-1FL-BF-O/S Rm 607-R	<1.00	15.5	No
2 CJCP-1FL-WC-O/S Rm 125-L	<1.00	15.5	No
3 CJCP-1FL-WC-O/S Rm 125-R	<1.00	15.5	No
4 CJCP-1FL-WC-O/S Rm 206-L	<1.00	15.5	No
5 CJCP-1FL-WC-O/S Rm 206-R	<1.00	15.5	No
6 CJCP-1FL-WC-O/S Rm 177 by Gym-L	<1.00	15.5	No
7 CJCP-1FL-WC-O/S Rm 106-L	<1.00	15.5	No
8 CJCP-1FL-WC-O/S Rm 106-C	<1.00	15.5	No
9 CJCP-1FL-WC-O/S Rm 106-R	<1.00	15.5	No
10 CJCP-1FL-WC-O/S Rm 116-L	<1.00	15.5	No
11 CJCP-1FL-WC-O/S Rm 116-R	<1.00	15.5	No
12 CJCP-GFL-WC-O/S Rm 317-L	<1.00	15.5	No
13 CJCP-GFL-WC-O/S Rm 317-R	<1.00	15.5	No
14 CJCP-GFL-WC-Teachers Lounge	<1.00	15.5	No
15 CJCP-GFL-WC-O/S Assembly-L	<1.00	15.5	No
16 CJCP-GFL-WC-O/S Assembly-R	<1.00	15.5	No
17 CJCP-2FL-WC-Business Admin Office	<1.00	15.5	No
18 Field Blank	<1.00	15.5	No

-END OF SECTION

5.0 DISCUSSION & RECOMMENDATIONS

Based on laboratory analysis of the samples analyzed, none of the first draw samples exceeded the action limit of 15.5 ug/L. Hence, the corresponding flush samples were not analyzed.

Action Required:

Currently, **no immediate action is required.**

-END OF SECTION-

6.0 DISCLAIMER

The type of samples collected for this assessment are referred to as grab samples. Grab samples are individual discrete samples collected at a specific time and location.

No guarantee or warranty of the findings and conclusions is implied within the intent of this report. It is limited to only those items listed in the report and is a snapshot of the conditions existing at the time of the assessment as conditions may vary with time.

WCE assumes no liability with regards to decisions made or the use of any information contained in this report, which is prepared exclusively for and is confidential to the above noted client. These services are designed to provide an analytical tool to assist the client, and the user(s) of this information must use their own best judgment to determine the appropriate course of action.

Westchester Environmental LLC



Christopher Piccininni
Environmental Specialist

-END OF REPORT-

APPENDIX I

LEAD IN DRINKING WATER SAMPLING CHAINS-OF-CUSTODY & LAB REPORTS



SUBURBAN TESTING LABS

Results Report

Order ID: 5D05356

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: Central Jersey College Prep-Central Jersey Prep Charter
School
101 Mettlers Rd,
Somerset NJ 08873

Attn: Christopher Piccininni

Regulatory ID:

Sample Number: 5D05356-01
Collector: CMP

Site: CJCP-1FL-BF-O/S Rm 607-R
Collect Date: 04/12/2025 8:05 am

Sample ID: First 001
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/17/25 JJA 04/18/25 1:18 RPV

Sample Number: 5D05356-02
Collector: CMP

Site: CJCP-1FL-WC-O/S Rm 125-L
Collect Date: 04/12/2025 8:07 am

Sample ID: First 002
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/17/25 JJA 04/18/25 1:25 RPV

Sample Number: 5D05356-03
Collector: CMP

Site: CJCP-1FL-WC-O/S Rm 125-R
Collect Date: 04/12/2025 8:09 am

Sample ID: First 003
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/17/25 JJA 04/18/25 1:29 RPV

Sample Number: 5D05356-04
Collector: CMP

Site: CJCP-1FL-WC-O/S Rm 206-L
Collect Date: 04/12/2025 8:11 am

Sample ID: First 004
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/17/25 JJA 04/18/25 1:32 RPV

Sample Number: 5D05356-05
Collector: CMP

Site: CJCP-1FL-WC-O/S Rm 206-R
Collect Date: 04/12/2025 8:13 am

Sample ID: First 005
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/17/25 JJA 04/18/25 1:35 RPV

Report Generated On: 04/25/2025 9:18 am
STL_Results Revision #3.0

5D05356
Effective: 05/29/2024

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
NJDEP# PA081



SUBURBAN TESTING LABS

Sample Number: 5D05356-06 Site: CJCP-1FL-WC-O/S Rm 177 by Gym-L Sample ID: First 006
Collector: CMP Collect Date: 04/12/2025 8:15 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/18/25 1:39	RPV
------	--------	------	-----------	------	--	---	----------	-----	---------------	-----

Sample Number: 5D05356-07 Site: CJCP-1FL-WC-O/S Rm 106-L Sample ID: First 007
Collector: CMP Collect Date: 04/12/2025 8:17 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/18/25 1:53	RPV
------	--------	------	-----------	------	--	---	----------	-----	---------------	-----

Sample Number: 5D05356-08 Site: CJCP-1FL-WC-O/S Rm 106-C Sample ID: First 008
Collector: CMP Collect Date: 04/12/2025 8:19 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/23/25 17:34	RPV
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 5D05356-09 Site: CJCP-1FL-WC-O/S Rm 106-R Sample ID: First 009
Collector: CMP Collect Date: 04/12/2025 8:21 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/23/25 17:48	RPV
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 5D05356-10 Site: CJCP-1FL-WC-O/S Rm 116-L Sample ID: First 010
Collector: CMP Collect Date: 04/12/2025 8:23 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/23/25 17:51	RPV
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 5D05356-11 Site: CJCP-1FL-WC-O/S Rm 116-R Sample ID: First 011
Collector: CMP Collect Date: 04/12/2025 8:25 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/23/25 17:55	RPV
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 5D05356-12 Site: CJCP-GFL-WC-O/S Rm 317-L Sample ID: First 012
Collector: CMP Collect Date: 04/12/2025 8:27 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/23/25 17:58	RPV
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Report Generated On: 04/25/2025 9:18 am 5D05356
STL_Results Revision #3.0 Effective: 05/29/2024

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
NJDEP# PA081



SUBURBAN TESTING LABS

Sample Number: 5D05356-13 Site: CJCP-GFL-WC-O/S Rm 317-R Sample ID: First 013
Collector: CMP Collect Date: 04/12/2025 8:29 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/23/25 18:02	RPV
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 5D05356-14 Site: CJCP-GFL-WC-Teachers Lounge Sample ID: First 014
Collector: CMP Collect Date: 04/12/2025 8:31 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/23/25 18:05	RPV
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 5D05356-15 Site: CJCP-GFL-WC-O/S Assembly-L Sample ID: First 015
Collector: CMP Collect Date: 04/12/2025 8:33 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/23/25 18:09	RPV
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 5D05356-16 Site: CJCP-GFL-WC-O/S Assembly-R Sample ID: First 016
Collector: CMP Collect Date: 04/12/2025 8:35 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/23/25 18:12	RPV
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 5D05356-17 Site: CJCP-2FL-WC-Business Admin Office Sample ID: First 017
Collector: CMP Collect Date: 04/12/2025 8:37 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/23/25 18:15	RPV
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 5D05356-18 Site: Field Blank Sample ID: First 018
Collector: CMP Collect Date: 04/12/2025 8:39 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	04/17/25	JJA	04/18/25 1:56	RPV
------	--------	------	-----------	------	--	---	----------	-----	---------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 04/25/2025 9:18 am 5D05356
STL_Results Revision #3.0 Effective: 05/29/2024

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
NJDEP# PA081



SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's NELAP Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lauren Ulle

Project Manager I

Report Generated On: 04/25/2025 9:18 am

5D05356

STL_Results Revision #3.0


Effective: 05/29/2024

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
NJDEP# PA081



5005356
Lauren Uile



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.	Project Name:	Central Jersey College Prep
Address:	1248 Wrights Lane	Address:	Central Jersey Prep Charter School
Contact Name:	Chris Piccininni	Address:	101 Mettlers Rd, Somerset, NJ 08873
Phone:	610-431-7545	Payment / P.O. Info:	
Email:	cpiccininni@westchesterenv.com		

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	CJCP-1FL-BF-o/s Rm 607-R	04/12/25	08:05 AM	CMP	001	Pb EPA 200.8	1	PW	G	P	H	BF o/s Rm 607
First	CJCP-1FL-WC-o/s Rm 125-L	04/12/25	08:07 AM	CMP	002	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 125
First	CJCP-1FL-WC-o/s Rm 125-R	04/12/25	08:09 AM	CMP	003	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 125
First	CJCP-1FL-WC-o/s Rm 206-L	04/12/25	08:11 AM	CMP	004	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 206
First	CJCP-1FL-WC-o/s Rm 206-R	04/12/25	08:13 AM	CMP	005	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 206
First	CJCP-1FL-WC-o/s Rm 177 by Gym-L	04/12/25	08:15 AM	CMP	006	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 177 by Gym
First	CJCP-1FL-WC-o/s Rm 106-L	04/12/25	08:17 AM	CMP	007	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 106
First	CJCP-1FL-WC-o/s Rm 106-C	04/12/25	08:19 AM	CMP	008	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 106
First	CJCP-1FL-WC-o/s Rm 106-R	04/12/25	08:21 AM	CMP	009	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 106
First	CJCP-1FL-WC-o/s Rm 116-L	04/12/25	08:23 AM	CMP	010	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 116

Comments:

11012509L 04/12/25 - PK 2
4-15-25
CTB

Relinquished By: Ang DeViney Date: 4/14/25 Time: 8:00 AM

Received By: Ang DeViney Date: 4-15-25 Time: 12:22 Temp °C: Acceptable Y/N

Relinquished By: Ang DeViney Date: 4-15-25 Time: 1445 Temp °C: Acceptable Y/N

Received In Lab By: CTB Date: 4-15-25 Time: 1804 Temp °C: 21.2 Acceptable Y/N: N/A

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ GOC	NPW = Non-Potable Water	P = Plastic
Number of containers match	Solid = Raw Sludge Dispensed PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Prohibit Sample	G = Glass O = Other
All containers intact	SWDA Sample Type	Preservative Key
Tests within holding times	G = Grab B HC = 8 Hour Composite 24 HC = 24 Hour Composite	Thiosulphate Add O = HCl H ₂ SO ₄ NaOH
40 ml VOA vials free of headspace?	D = Distribution E = Entry Point R = Raw C = Check S = Special M = Minimum Residence	H = Sodium A = Ascorbic H = HNCB S = OH = O = Other NA = None Required



5005356
Lauren Uille



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-376-TEST - Fax: 610-376-4090 - suburban.testinglabs.com

1A1 (Neck One)

Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.	Project Name:	Central Jersey College Prep
Address:	1248 Wrights Lane	Address:	Central Jersey Prep Charter School
Contact Name:	Chris Piccininni	Address:	101 Mettlers Rd, Somerset, NJ 08873
Phone:	610-431-7545	Payment / P.O. Info:	
Email:	cpiccininni@westchesternj.com		

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	CJCP-1FL-WC-o/s Rm 116-R	04/12/25	08:25 AM	CMP	011	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 116
First	CJCP-GFL-WC-o/s Rm 317-L	04/12/25	08:27 AM	CMP	012	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 317
First	CJCP-GFL-WC-o/s Rm 317-R	04/12/25	08:29 AM	CMP	013	Pb EPA 200.8	1	PW	G	P	H	WC o/s Rm 317
First	CJCP-GFL-WC-Teachers Lounge	04/12/25	08:31 AM	CMP	014	Pb EPA 200.8	1	PW	G	P	H	Teachers Lounge
First	CJCP-GFL-WC-o/s Assembly-L	04/12/25	08:33 AM	CMP	015	Pb EPA 200.8	1	PW	G	P	H	WC o/s Assembly
First	CJCP-GFL-WC-o/s Assembly-R	04/12/25	08:35 AM	CMP	016	Pb EPA 200.8	1	PW	G	P	H	WC o/s Assembly
First	CJCP-2FL-WC-Business Admin Office	04/12/25	08:37 AM	CMP	017	Pb EPA 200.8	1	PW	G	P	H	Business Admin WC
First	Field Blank	04/12/25	08:39 AM	CMP	018	Pb EPA 200.8	1	PW	G	P	H	Field Blank

Relinquished by:

Date: 4/14/25
Time: 8:00 AM

Received By:

Date: 4/15/25
Time: 12:22
Temp °C: Acceptable Y/N

Relinquished by:

Date: 4/15/25
Time: 1445
Temp °C: Acceptable Y/N

Received in Lab By:

Date: 4/15/25
Time: 1804
Temp °C: 21.2
Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ DOC	NPW = Non-Potable Water Solid = Raw Sludge Sludge not etc. (reported as high)	P = Plastic G = Glass O = Other
Number of containers match	PW = Potable Water (not for SWDA compliance)	Preservative Key
All containers intact	Potable Sample SWDA = Safe Drinking Water Act	Thiosulfate Ascorbic Acid C = HCl H ₂ SO ₄ NaOH
Tests within holding times	Sample Type Key	H = Sodium A = Ascorbic H = HNO ₃ OH = O = Other NA = None Required
40 mL VOA vials free of headspace?	SWDA Sample Type	
	G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	